



CITY OF ATLANTA

Kasim Reed
Mayor

SUITE 1900
55 TRINITY AVENUE, SW
ATLANTA, GA 30303
(404) 330-6204 Fax: (404) 658-7705
Internet Home Page: www.atlantaga.gov

DEPARTMENT OF PROCUREMENT
Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP
Chief Procurement Officer
asmith@atlantaga.gov

January 12, 2015

Dear Potential Bidders:

Re: FC-7791, Annual Contract for Water Facilities Installation

Attached is one (1) copy of **Addendum Number 2**, which is hereby made a part of the above-referenced project.

For additional information, please contact Lloyd A. Richardson, Contracting Officer, at (404) 864-8504, or by email at larichardson@atlantaga.gov.

Sincerely,


Adam L. Smith

ALS/lar

ADDENDUM NO. 2

This Addendum No. 2 forms a part of the Invitation to Bid and modifies the original solicitation package and any prior Addenda as noted below and is issued to incorporate the following:

- **Questions and Answers**

Total of four (4) questions attached hereto as Attachment No. 1.

The Bid due date HAS NOT been modified and Bids are due on Wednesday, January 14, 2015 and should be time stamped in no later than 2:00 P.M. EST and delivered to the address listed below:

Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP
Chief Procurement Officer
Department of Procurement
55 Trinity Avenue, S. W.
City Hall South, Suite 1900
Atlanta, Georgia 30303

****All other pertinent information is to remain unchanged****

FC-7791, Annual Contract for Water Facilities Installation
Addendum No. 2
January 12, 2015
Page 3

Acknowledgment of Addendum No. 2

Bidders must sign below and return this form with Bid response to the Department of Procurement.

Bidders must sign below and return this form with Bid to the Department of Procurement, 55 Trinity Avenue S.W., City Hall South, Suite 1900, Atlanta, Georgia 30303 as acknowledgment of receipt of this Addendum.

This is to acknowledge receipt of **FC-7791, Annual Contract for Water Facilities Installation** on this the _____ day of _____, 20__.

Legal Company Name of Bidder

Signature of Authorized Representative

Printed Name

Title

Date

Attachment 1

Questions and Answers

Questions and Answers

FC-7791, Annual Contract for Water Facilities Installation

Questions 1: Bid Item # 123: Type B Base for Permanent Asphalt pavement Replacement. What will be depth for the asphalt base?

Answer: Specification page 02700-5, paragraph 3.02, A, specifies pavement type and thickness to match existing pavement removed, unless otherwise directed by the Engineer.

Questions 2: Bid Item # 124: Type E topping for permanent asphalt pavement replacement. What will be thickness for topping?

Answer: Specification page 02700-8, paragraph 3.06, A, 1, c, specifies thickness for surface pavement of milled City streets as two (2) inches.

Questions 3: Bid Item # 125: Super pave for permanent asphalt pavement replacement. What will be thickness for super pave?

Answer: Specification page 02700-3, paragraph 2.01, F. 2, specifies thickness for surface pavement as 12.5mm. In addition, Specification page 02700-9, paragraph 3.06, A, 2, c requires superpave be placed to the thickness of milling.

Questions 4: Bid Item # 126: Pavement milling. What will be depth for milling and paving?

Answer: Specification page 02700-8, paragraph 3.06, A, 1, a, specifies thickness for milling of City streets as 2 inches. Specification page 02700-9, paragraph 3.06, A, 2, a, specifies milling of roads under jurisdiction of Georgia Department of Transportation (GDOT) shall be two (2) inches, or as directed by the Engineer.